

**DRC**  
**SITE PLAN REVIEW AND COMMENT**  
**REPORT**

**Division:** Zoning

**Member:** Terry Burgess  
761-5913

**Project Name:** Corporate Properties Holdings, Inc. et al  
**Case #:** 1-P-01

**Date:** 1/29/01

**Comments:**

1. No comments.

**DRC**  
**SITE PLAN REVIEW AND COMMENT**  
**REPORT**

**Division:** Plumbing

**Member:** Ted DeSmith  
761-5232

**Project Name:** Corporate Properties Holdings, Inc., et al  
**Case #:** 1-P-01

**Date:** February 4, 2001

**Comments:**

1. No comments

**DRC**  
**SITE PLAN REVIEW AND COMMENT**  
**REPORT**

Division: Police

Member: Robert Dodder  
759-6421  
Beeper 497-0628

Project Name: Corporate Prop. Holdings

Case #: 1-P-01

Date: 02-06

**Comments:**

No Comment.

**DRC**  
**SITE PLAN REVIEW AND COMMENT**  
**REPORT**

**Division:** Landscape

**Member:** Dave Gennaro  
761-5200

**Project Name:** Corporate Properties Holdings, Inc.

**Case #:** 1-P-01

**Date:** 2/7/01

**Comments:**

No comments

**DRC**  
**SITE PLAN REVIEW AND COMMENT**  
**REPORT**

**Division:** Construction Services

**Member:** John R. Smith  
761-5220

**Project Name:** Corporate Properties Holdings, Inc.

**Case #:** 1-P-01

**Date:** February 13, 2001

**Comments:**

1. No comments.

**DRC**  
**SITE PLAN REVIEW AND COMMENT**  
**REPORT**

**Division:** Engineering

**Member:** Tim Welch  
761-5123

**Project Name:** Corporate Properties Holdings, Inc

**Case #:** 1-P-01

**Date:** February 7, 2001

**Comments:**

1. Please provide a copy of the proposed plat to Tony Irvine, City Surveyor, for his review and final authorization along with Tim Welch's.
2. Provided sketch shows a 100 ft existing right-of-way width for Federal Highway (U.S 1). A 120 ft. width is required by the Broward County Trafficways Plan. Please indicate this additional dedication to occur on this plat as submitted for County's review, with appropriate corner chords as required by the Florida Dept. of Transportation.
3. Provided sketch shows a 100 ft existing right-of-way width for SE 24<sup>th</sup> Street. A 120 ft. width is required by the Broward County Trafficways Plan. Corresponding dedication of right of way and corner chords shall also be dedicated by plat with submittal to Broward Co. and as approved by the FDOT.

**DRC**  
**SITE PLAN REVIEW AND COMMENT**  
**REPORT**

**Division:** Info. Systems

**Member:** Mark Pallans (GRG)  
828-5790

**Project Name:** Corporate Properties Holdings, Inc.,  
Et al

**Case #:** 1-P-01

**Date:** February 13, 2001

**Comments:**

No apparent interference will result from this plan at this time.